

**Annual Drinking Water Quality Report 2023
Covering Calendar Year 2022**

**Clay-Roane Public Service District
1100 Elk River Road, Prociou, WV 25164
PWSID# 3300806**

**Clay County Public Service District
247 Main St, P. O. Box 130 Clay, WV 25043
PWSID# 3300809
PWSID# 3300810
PWSID# 3300811**

May 4, 2023

Why am I receiving this report?

In compliance with the Safe Drinking Water Act Amendments, **the Clay-Roane PSD, Clay County PSD**, is providing their customers with this annual water quality report. This report explains where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. The information in this report shows the results of our monitoring for the period of January 1st to December 31st, 2022 or earlier if not on a yearly schedule.

If you have any questions concerning this report, you may contact General Manager, **Crystal Adkins at 304-548-5209 for those customers being served by Clay-Roane PSD**. If you have any further questions, comments or suggestions, please attend any of our regularly scheduled board meetings held on the **2nd Thursday of every month at 6:30pm on Zoom**.

If you have any questions concerning this report, you may contact **Beverly Pierson at 304-587-7579 for those customers being served by the Clay County PSD**. If you have any further questions, comments or suggestions, please attend any of our regularly scheduled board meetings held on the **2nd Thursday of every month at 11:00 AM at the Clay County PSD office located on 247 Main Street in Clay West Virginia**.

Where does my water come from?

Your water source is **surface** water from the Elk River.

Clay County PSD **purchases** your drinking water from the Clay Municipal Water Works which uses **surface** water from the Elk River

Source Water Assessment

A Source Water Assessment was conducted in 2015 by the West Virginia Bureau for Public Health (WVBPH). The intake that supplies drinking water to the town of **Clay and the Clay-Roane PSD** has a higher susceptibility to contamination, due to the sensitive nature of surface water supplies and the potential contaminant sources identified within the area. This does not mean that these intakes will become contaminated; only that conditions are such that the surface water could be impacted by a potential contaminant source. Future contamination may be avoided by implementing protective measures. The source water assessment report which contains more information is available for review or a copy will be provided to you at our office during business hours or from the WVBPH 304-558-2981.

Why must water be treated?

All drinking water contains various amounts and kinds of contaminants. Federal and state regulations establish limits, controls, and treatment practices to minimize these contaminants and to reduce any subsequent health effects.

Contaminants in Water

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits of contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The source of drinking water (both tap and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals, and, in some cases radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring, or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Water Quality Data Table

Definitions of terms and abbreviations used in the table or report:

- **MCLG - Maximum Contaminant Level Goal**, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL - Maximum Contaminant Level**, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technique.
- **MRDLG - Maximum Residual Disinfectant Level Goal**, or the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect benefits of use of disinfectants to control microbial contaminants.
- **MRDL - Maximum Residual Disinfectant Level**, or the highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary to control microbial contaminants.
- **AL** – Action level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **TT - Treatment Technique**, or a required process intended to reduce the level of a contaminant in drinking water.

Abbreviations that may be found in the table:

- **ppm** - parts per million or milligrams per liter
- **ppb** - parts per billion or micrograms per liter
- **NTU** - Nephelometric Turbidity Unit, used to measure cloudiness in water!

- **NE** - not established
- **N/A** - not applicable
- **MDL** - Maximum Detection Level
- **ND** - Non-Detect, lab analysis indicates non-detect at or above Maximum Detection Level
- **pCi/L** - Picocuries per Liter, a measure of the radioactivity in water
- **mrem/yr** - Millirems per Year, measure of radiation absorbed by the body
- **MPA** - Monitoring Period Average, an average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly, and yearly
- **RAA** - Running Annual Average, an average of sample results obtained over the most current 12 months and are used to determine compliance with MCL's
- **LRAA** – Location Running Annual Average, average of sample results for a sample taken at a particular monitoring location during the previous four calendar quarters

The **Clay-Roane PSD, and Clay County PSD**, routinely monitor for contaminants in your drinking water according to federal and state laws. The tables below show the results of our monitoring for contaminants.

Testing Results for: CLAY-ROANE PSD (PROCIOS DISTRICT)

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2022				

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	3/23/2021	0.0286	0.0286	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
NITRATE	3/23/2021	0.39	0.39	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	3/23/2021	0.39	0.39	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Monitoring Period	Highest LRAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	REED FORK - ADKINS RESIDENCE	2022	29	12 - 33.9	ppb	60	0	By-product of drinking water disinfection
TTHM	REED FORK - ADKINS RESIDENCE	2022	23	10 - 35.4	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2020 - 2022	0.274	0 - 0.602	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2020 - 2022	1.5	0 - 29.6	ppb	15	1	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

CLAY-ROANE PSD (PROCIOS DISTRICT) is working towards identifying service line materials throughout the water distribution supply. The service line inventory is required to be submitted to the state by October 16, 2024. The most up to date inventory is located Clay Roane Public Service District Office, if you have any questions about our inventory, please contact CRYSTAL D. ADKINS at 304-548-5209.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
2022 - 2022	2.0000	MG/L	1.4	MG/L

Total Organic Carbon Lowest Month for Removal	Collection Date	Highest Value	Range	Unit	TT	Typical Source
CARBON, TOTAL	8/23/2022	1.4	0 - 1.4	MG/L	0	Naturally present in the environment

	Monitoring Period	MCL	Range (low/high)	Unit	Lowest monthly % <0.3 NTU (TT if < 95%)	Violation	Typical Source
TURBIDITY	2022	TT=1 NTU	0.03 - 0.28	NTU	100%	No	Soil runoff and erosion

Radiological Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
GROSS ALPHA, EXCL. RADON & U	3/7/2022	-0.368	-0.368	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	3/7/2022	0.135	0.135	pCi/L	5	0	Erosion of natural deposits

COMBINED URANIUM	3/7/2022	0.019	0.019	ppb	30	0	Erosion of natural deposits
------------------	----------	-------	-------	-----	----	---	-----------------------------

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	7/27/2022	35.2	14 - 35.2	MG/L	10000
CARBON, TOTAL	8/23/2022	4.1	0 - 4.1	ppm	10000
NICKEL	3/23/2021	0.00066	0.00066	MG/L	0.1
PH	4/11/2018	7.6	7.6	SU	8.5
SODIUM	3/23/2021	7.28	7.28	MG/L	1000
SULFATE	3/23/2021	27.8	27.8	MG/L	250

During the 2022 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
3/1/2022 - 5/31/2022	TTHM	MONITORING, ROUTINE (DBP), MAJOR
10/1/2022 - 12/31/2022	CARBON, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
10/1/2022 - 12/31/2022	CARBON, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
10/1/2022 - 12/31/2022	ALKALINITY, TOTAL	MONITORING, ROUTINE (DBP), MAJOR
10/1/2022 - 12/31/2022	TOTAL HALOACETIC ACIDS (HAA5)	MONITORING, ROUTINE (DBP), MAJOR
10/1/2022 - 12/31/2022	TTHM	MONITORING, ROUTINE (DBP), MAJOR
1/1/2022 - 12/31/2022	VOC'S	MONITORING, ROUTINE (DBP), MAJOR
1/1/2020 - 12/31/2022	SOC'S	MONITORING, ROUTINE (DBP), MAJOR
1/1/2022 - 12/31/2022	ARSENIC TOTAL	MONITORING, ROUTINE (DBP), MAJOR
1/1/2022 - 12/31/2022	INORGANICS	MONITORING, ROUTINE (DBP), MAJOR
10/1/2022 - 12/31/2022	PUBLIC NOTICE	PUBLIC NOTICE LINKED TO VIOLATION

Additional Required Health Effects Language:

Infants and children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4761).

There are no additional required health effects violation notices.

Testing Results for: CLAY CO P S D - IVYDALE

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2022				

Disinfection Byproducts	Sample Point	Monitoring Period	Highest LRAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	LAUREL NURSING HOME	2022	63	27 - 49	ppb	60	0	By-product of drinking water disinfection
TTHM	LAUREL NURSING HOME	2022	62	20.8 - 63	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2019 - 2021	0.0268	0.0023 - 0.0449	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2019 - 2021	0.34	0.12 - 1.4	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

CLAY CO P S D - IVYDALE is working towards identifying service line materials throughout the water distribution supply. The service line inventory is required to be submitted to the state by October 16, 2024. The most up to date inventory is located Clay County Public Service District Office, if you have any questions about our inventory, please contact BEVERLY S. PIERSON at 304-587-7579.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
2022 - 2022	1.2000	MG/L	0.8	MG/L

During the 2022 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
1/11/2022 - 1/14/2022	STATE RESIDUAL CHLORINE	AUTOMATED BWN CERT

Additional Required Health Effects Language:

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

There are no additional required health effects violation notices.

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2022 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	4/12/2022	CLAY WATER DEPT	0.0265	0.0265	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
NITRATE	9/13/2022	CLAY WATER DEPT	0.23	0.23	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	7/13/2021	CLAY WATER DEPT	0.11	0.11	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
GROSS ALPHA, EXCL. RADON & U	9/13/22	CLAY WATER DEPT	0.221	0.221	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	9/13/22	CLAY WATER DEPT	0.476	0.476	pCi/L	5	0	Erosion of natural deposits

Secondary Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	11/10/2022	CLAY WATER DEPT	33.6	8.8 - 33.6	MG/L	10000
ALUMINUM	5/12/2022	CLAY WATER DEPT	13.7	0.62 - 13.7	MG/L	0.05
BORON, TOTAL	7/13/2021	CLAY WATER DEPT	9.4	8.6 - 9.4	UG/L	
CALCIUM	8/17/2021	CLAY WATER DEPT	14400	12800 - 14400	UG/L	
CARBON, TOTAL	3/8/2022	CLAY WATER DEPT	1.9	0 - 1.9	ppm	10000
CHLORIDE	7/13/2021	CLAY WATER DEPT	8.7	7.9 - 8.7	MG/L	250
CHLORINE	12/3/2019	CLAY WATER DEPT	1.4	1.4	MG/L	4
GIARDIA LAMBLIA	12/3/2019	CLAY WATER DEPT	1	0 - 1		1
IRON	5/12/2022	CLAY WATER DEPT	0.636	0.041 - 0.636	MG/L	0.3
MAGNESIUM	8/17/2021	CLAY WATER DEPT	6840	4.2 - 6840	UG/L	
MANGANESE	5/12/2022	CLAY WATER DEPT	0.224	0.098 - 0.224	MG/L	0.05
PH	5/18/2020	CLAY WATER DEPT	8.9	8.9	SU	8.5
POTASSIUM	8/17/2021	CLAY WATER DEPT	1540	1330 - 1540	UG/L	
SODIUM	8/17/2021	CLAY WATER DEPT	7.93	5.71 - 7.93	MG/L	1000
SULFATE	8/17/2021	CLAY WATER DEPT	37.8	29.9 - 37.8	MG/L	250
ZINC	7/13/2021	CLAY WATER DEPT	0.0056	0.0025 - 0.0056	MG/L	5

Please Note: Because of sampling schedules, results may be older than 1 year.

During the 2022 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
CLAY WATER DEPT	MONITORING, ROUTINE MAJOR	MON	SODIUM	1/1/2022 - 12/31/2022
CLAY WATER DEPT	FAILURE ADDRESS DEFICIENCY (EPA SURVEY)	TT	LT2ESWTR	9/2/2022
CLAY WATER DEPT	FAILURE ADDRESS DEFICIENCY (EPA SURVEY)	TT	LT2ESWTR	9/2/2022

There are no additional required health effects violation notices.

There are no additional required health effects notices.

This Consumer Confidence Report is not being mailed to each customer. A copy can be provided upon request by calling our office at 304-587-7579.

Testing Results for: CLAY CO P S D-TRIPLETT RIDGE

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2022				

Disinfection Byproducts	Sample Point	Monitoring Period	Highest LRAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	4476 TRIPLETT RIDGE DOH	2022	32	24 - 40	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	INACT- 3422 TRIPLETT RDG RD	2022	40	18 - 49	ppb	60	0	By-product of drinking water disinfection
TTHM	4476 TRIPLETT RIDGE DOH	2022	60	39 - 60	ppb	80	0	By-product of drinking water chlorination
TTHM	INACT- 3422 TRIPLETT RDG RD	2022	69	14 - 37	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2018 - 2020	0.0015	0.00079 - 0.0021	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2018 - 2020	0.27	0 - 0.32	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

CLAY CO P S D-TRIPLETT RIDGE is working towards identifying service line materials throughout the water distribution supply. The service line inventory is required to be submitted to the state by October 16, 2024. The most up to date inventory is located Clay County Public Service District Office, if you have any questions about our inventory, please contact BEVERLY S. PIERSON at 304-587-7579.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
2022 - 2022	1.4600	MG/L	0.9	MG/L

During the 2022 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
1/11/2022 - 1/14/2022	STATE RESIDUAL CHLORINE	AUTOMATED BWN CERT

There are no additional required health effects notices.

There are no additional required health effects violation notices.

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2022 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	4/12/2022	CLAY WATER DEPT	0.0265	0.0265	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
NITRATE	9/13/2022	CLAY WATER DEPT	0.23	0.23	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	7/13/2021	CLAY WATER DEPT	0.11	0.11	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
GROSS ALPHA, EXCL. RADON & U	9/13/22	CLAY WATER DEPT	0.221	0.221	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	9/13/22	CLAY WATER DEPT	0.476	0.476	pCi/L	5	0	Erosion of natural deposits

Secondary Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	11/10/2022	CLAY WATER DEPT	33.6	8.8 - 33.6	MG/L	10000
ALUMINUM	5/12/2022	CLAY WATER DEPT	13.7	0.62 - 13.7	MG/L	0.05
BORON, TOTAL	7/13/2021	CLAY WATER DEPT	9.4	8.6 - 9.4	UG/L	
CALCIUM	8/17/2021	CLAY WATER DEPT	14400	12800 - 14400	UG/L	
CARBON, TOTAL	3/8/2022	CLAY WATER DEPT	1.9	0 - 1.9	ppm	10000
CHLORIDE	7/13/2021	CLAY WATER DEPT	8.7	7.9 - 8.7	MG/L	250
CHLORINE	12/3/2019	CLAY WATER DEPT	1.4	1.4	MG/L	4
GIARDIA LAMBLIA	12/3/2019	CLAY WATER DEPT	1	0 - 1		1
IRON	5/12/2022	CLAY WATER DEPT	0.636	0.041 - 0.636	MG/L	0.3
MAGNESIUM	8/17/2021	CLAY WATER DEPT	6840	4.2 - 6840	UG/L	
MANGANESE	5/12/2022	CLAY WATER DEPT	0.224	0.098 - 0.224	MG/L	0.05
PH	5/18/2020	CLAY WATER DEPT	8.9	8.9	SU	8.5
POTASSIUM	8/17/2021	CLAY WATER DEPT	1540	1330 - 1540	UG/L	
SODIUM	8/17/2021	CLAY WATER DEPT	7.93	5.71 - 7.93	MG/L	1000
SULFATE	8/17/2021	CLAY WATER DEPT	37.8	29.9 - 37.8	MG/L	250
ZINC	7/13/2021	CLAY WATER DEPT	0.0056	0.0025 - 0.0056	MG/L	5

Please Note: Because of sampling schedules, results may be older than 1 year.

During the 2022 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
CLAY WATER DEPT	MONITORING, ROUTINE MAJOR	MON	SODIUM	1/1/2022 - 12/31/2022
CLAY WATER DEPT	FAILURE ADDRESS DEFICIENCY (EPA SURVEY)	TT	LT2ESWTR	9/2/2022
CLAY WATER DEPT	FAILURE ADDRESS DEFICIENCY (EPA SURVEY)	TT	LT2ESWTR	9/2/2022

There are no additional required health effects violation notices.

There are no additional required health effects notices.

This Consumer Confidence Report is not being mailed to each customer. A copy can be provided upon request by calling our office at 304-587-7579.

Testing Results for: CLAY CO PSD-HARTLAND

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2022				

Disinfection Byproducts	Sample Point	Monitoring Period	Highest LRAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	FOLA BOOSTER STATION 855 FOLA RD	2022	44	25 - 70	ppb	60	0	By-product of drinking water disinfection
TTHM	LITTLE GENERAL 13992 CLAY HWY	2022	77	14 - 48.14	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 th Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2019 - 2021	0.0053	0.00053 - 0.0426	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2019 - 2021	1.1	0 - 2	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

CLAY CO PSD-HARTLAND is working towards identifying service line materials throughout the water distribution supply. The service line inventory is required to be submitted to the state by October 16, 2024. The most up to date inventory is located at the Clay County Public Service District Office, if you have any questions about our inventory, please contact BEVERLY S. PIERSON at 304-587-7579.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
2022 - 2022	1.7500	MGL	1.0	MG/L

During the 2022 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
1/11/2022 - 1/14/2022	STATE RESIDUAL CHLORINE	AUTOMATED BWN CERT

Additional Required Health Effects Language:

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

There are no additional required health effects violation notices.

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2022 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	4/12/2022	CLAY WATER DEPT	0.0265	0.0265	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
NITRATE	9/13/2022	CLAY WATER DEPT	0.23	0.23	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	7/13/2021	CLAY WATER DEPT	0.11	0.11	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
GROSS ALPHA, EXCL. RADON & U	9/13/22	CLAY WATER DEPT	0.221	0.221	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	9/13/22	CLAY WATER DEPT	0.476	0.476	pCi/L	5	0	Erosion of natural deposits

Secondary Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	11/10/2022	CLAY WATER DEPT	33.6	8.8 - 33.6	MG/L	10000
ALUMINUM	5/12/2022	CLAY WATER DEPT	13.7	0.62 - 13.7	MG/L	0.05
BORON, TOTAL	7/13/2021	CLAY WATER DEPT	9.4	8.6 - 9.4	UG/L	
CALCIUM	8/17/2021	CLAY WATER DEPT	14400	12800 - 14400	UG/L	
CARBON, TOTAL	3/8/2022	CLAY WATER DEPT	1.9	0 - 1.9	ppm	10000
CHLORIDE	7/13/2021	CLAY WATER DEPT	8.7	7.9 - 8.7	MG/L	250
CHLORINE	12/3/2019	CLAY WATER DEPT	1.4	1.4	MG/L	4
GIARDIA LAMBLIA	12/3/2019	CLAY WATER DEPT	1	0 - 1		1
IRON	5/12/2022	CLAY WATER DEPT	0.636	0.041 - 0.636	MG/L	0.3
MAGNESIUM	8/17/2021	CLAY WATER DEPT	6840	4.2 - 6840	UG/L	
MANGANESE	5/12/2022	CLAY WATER DEPT	0.224	0.098 - 0.224	MG/L	0.05
PH	5/18/2020	CLAY WATER DEPT	8.9	8.9	SU	8.5
POTASSIUM	8/17/2021	CLAY WATER DEPT	1540	1330 - 1540	UG/L	
SODIUM	8/17/2021	CLAY WATER DEPT	7.93	5.71 - 7.93	MG/L	1000
SULFATE	8/17/2021	CLAY WATER DEPT	37.8	29.9 - 37.8	MG/L	250
ZINC	7/13/2021	CLAY WATER DEPT	0.0056	0.0025 - 0.0056	MG/L	5

Please Note: Because of sampling schedules, results may be older than 1 year.

During the 2022 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
CLAY WATER DEPT	MONITORING, ROUTINE MAJOR	MON	SODIUM	1/1/2022 - 12/31/2022
CLAY WATER DEPT	FAILURE ADDRESS DEFICIENCY (EPA SURVEY)	TT	LT2ESWTR	9/2/2022
CLAY WATER DEPT	FAILURE ADDRESS DEFICIENCY (EPA SURVEY)	TT	LT2ESWTR	9/2/2022

There are no additional required health effects violation notices.

There are no additional required health effects notices.

This Consumer Confidence Report is not being mailed to each customer. A copy can be provided upon request by calling our office at 304-587-7579.

Additional Information:

Turbidity is the measure of cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

All other water test results for the reporting year 2018 were all non-detects.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The **Clay-Roane PSD, and Clay County PSD** are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead> at our offices during business hours.

This report will not be mailed. A copy will be made available for review or your use upon request.

System Name: Clay Roane PSD, Clay PSD Ivydale, Clay PSD Triplett, Clay PSD Hartland

PWS: WV3300806, WV3300809, WV3300810, WV3300811

Disclaimer: This document contains public information on the Water test results/ compliance issues for your Public Water System. The Consumer Confidence Report addresses public information state, and federal laws and regulations regarding your PWS.

Knowledgeable professionals prepared this document using current information obtained by the water system. The authors make no representation, expressed or implied, that this information is suitable for any specific situation. The authors have no obligation to update this work or to make notification of any changes in statutes, regulations, information, or programs described in this document. Publication of this document does not replace the duty of water systems to warn and properly inform their customers concerning health and safety risks and necessary precautions with their water systems compliance.

Rural Community Assistance Partnership, Inc. assumes no liability resulting from the use or reliance upon any information, guidance, suggestions, conclusions, or opinions contained in this document.

Print Name

5/4/2023

Date

Signature

